



MACON BIBB COUNTY FIRE STATION #111
3947 Jeffersonville Road / Macon, Georgia
BID NUMBER 16-057-NT
BTBB No. 15-037

25 May 2016

ADDENDUM NUMBER ONE

Bidders are advised that bidding documents on the above named project are amended as follows:

SPECIFICATIONS

1. Section 08710 – Finish Hardware: Par. 3.4, add the following hardware sets:

HW SET: 15
DOOR NUMBER: 10-202

EACH TO HAVE:

3	EA	HINGE	5BB1 5 X 5 NRP	600	IVE
1	EA	STORE ROOM LOCK	L9480 03A	626	SCH
1	EA	OVERHEAD HOLDER	816H	630	GLY
1	SET	SEALS	160V	AL	NGP
1	EA	DRIP CAP	16A	CL	NGP
1	EA	DOOR SWEEP	200NA	CL	NGP
1	EA	THRESHOLD	425	AL	NGP

HW SET: 16
DOOR NUMBER: 3-201

EACH TO HAVE:

3	EA	HINGE	5BB1 4.5 X 4.5 NRP	600	IVE
1	EA	STORE ROOM LOCK	L9480 03A	626	SCH
1	EA	OVERHEAD HOLDER	814h	630	GLY
1	SET	SEALS	160V	AL	NGP
1	EA	DRIP CAP	16A	CL	NGP
1	EA	DOOR SWEEP	200NA	CL	NGP
1	EA	THRESHOLD	425	AL	NGP

2. Section 15793 – Wall and Ceiling Unit Heaters: Par. 2.1.A, add “Raywall” as an approved manufacturer subject to the requirements of the specifications and drawings.
3. Section 15820 – Duct Accessories: Par. 2.8.A, add “Thermaflex” as an approved manufacturer subject to the requirements of the specifications and drawings.
4. Section 15855 – Diffusers, Registers, and Grilles: Par. 2.2.1, add “United Enertech” as an approved manufacturer subject to the requirements of the specifications and drawings.

DRAWINGS

1. Sht. C2:
 - A. Add the following Notes:
 6. Asphalt pavement section shall be in accordance with Georgia Dept. of Transportation, 2013 Specifications. A typical section of asphalt pavement shall be heavy duty, defined as follows:
 - 1.5" 12.5 mm Superpave
 - 0.5 Gal/S.Y. Tack Coat
 - 2" 19 mm Superpave
 - 0.5 Gal/S.Y. Tack Coat
 - 3" 25 mm Superpave
 - 10" GAB
 7. A typical section of asphalt replacement shall be light duty as defined in the *Subsurface Exploration and Geotechnical Engineering Evaluation for Macon-Bibb County Fire Station – Jeffersonville Road by GEC, Inc., dated December 1, 2015*, as follows:
 - 2" 9.5 mm Superpave
 - 0.5 Gal/S.Y. Prime Coat
 - 6" GAB
 - B. Widen proposed 10'-0" handicapped parking space closest to the building (van accessible) to 11'-0" by shifting curb/gutter toward front of the building. Adjust grades at grassed island, as required.
2. Sht. C4: Main Storm Drainage Pipe – beginning with Flared End Section (FES) E6 running west to east at Jeffersonville Road to FES E1, shift entire pipe inside GDOT right-of-way, including all Catch Basin Curb Inlet (CBCI) labeled E2, E3, E4, and E5.
3. Sht. A1.1
 - A. Data 111 and Toilet 112: Change depth dimension of spaces from 5'-9 ¼" to 7'-2" (face of stud to face of stud). Shift wall toward Hall 110, shift door #6 to apparatus bay, and decrease depth of Office 109 accordingly to allow for modifications.
 - B. Linen 116 and Toilet 118: Change width dimension of spaces from 4'-4 ¾" to 5'-2" (face of stud to face of stud). Decrease dimension of Officer 117 and Officer 119 accordingly to allow for modifications. Pair of doors #13 at Linen 116 will not be altered. Modify shelving at Linen 116 to new full-width of closet.

END OF ADDENDUM