



2300 Lake Park Drive
Suite 250
Smyrna, GA 30080
770-458-3005
Fax 770-458-8388

February 7, 2017

W & A Memo No. 16049-M01

To: Mack Cain – Mack Cain Design Studio @ Travis Pruitt & Associates

From: Bill Womack – Womack & Associates

Electrical Addendum – Freedom Park Girls Softball Fields - Macon, GA

Base Bid shall include the sports lighting system as currently designed and specified in the issued bid documents for the above stated project.

Electrical Alternate No. 1:

Musco Lighting may be bid Alternate No. 1 for Sports Lighting System for the above project. To be accepted, Musco Lighting must bid as Alternate No. 1, using the existing Electrical Specification Section 26 6550 Sports Lighting System including meeting the requirements of Paragraphs 26 6550-1.01-H and Paragraph 26 6550-3.01-A (which are not standards to Musco Lighting).

Electrical Alternate No. 2:

Musco Lighting may bid Alternate No. 2 for the above project. Alternate No. 2 may be the Standard Musco Lighting Sports Lighting System using the Musco composite concrete stump with Galvanized Steel pole and their standard 25 year warranty. If there are any other specific deviations from existing Specification Section 26 6500 Sports Lighting System, these must be identified, explained and submitted along with the Alternate No. 2 Bid.

NOTE:

Refer to Electrical Specification Paragraphs 26 6500-1.01-J and K. The pole manufacturer's shall design the pole foundations to these two paragraphs or may use the data in the Geotechnical Survey that is posted on the Macon-Bibb Website as per Addendum No. 2 for the soil bearing pressure for Paragraph 26 6550-1.01-K. for alternate designs or locations.