



Macon-Bibb County Government

Procurement Department

Government Center

700 Poplar Street, Suite 308

Macon, Georgia 31201

(478) 803-0550

Fax (478) 751-7252

Chauncey Wilmore
Senior Procurement Officer

July 30, 2018
ADDENDUM #1

To: ALL PROSPECTIVE FIRMS

Re: INVITATION FOR BIDS: **19-002-NT, Macon-Bibb Levee Seepage Repair**

The Invitation for Bids, referenced above, is modified as follows:

1. Question and Answer

Question: Note 3B on sheet 9 of 17 of the drawings requires the compacted soil fill to have particle size such that 40% passes the No. 200 sieve and 95 must pass the 2 inch sieve. Is that a minimum, maximum, or is there a range associated with that?

Answer: The percentages given are minimums, so the soil could have 50% or 60% passing the No 200 sieve and 100% could pass the 2 inch sieve.

Please incorporate this change into the Invitation for Bid and acknowledge receipt of this addendum on your bid form.

Sincerely,

Nan Tharpe

Nan Tharpe
Procurement Officer II