



## Macon-Bibb County Government

Procurement Department

Government Center

700 Poplar Street, Suite 308

Macon, Georgia 31201

(478) 803-0550

Fax (478) 751-7252

Chauncey Wilmore  
Senior Procurement Officer

July 31, 2018  
ADDENDUM #2

To: ALL PROSPECTIVE FIRMS

Re: INVITATION FOR BIDS: **19-002-NT, Macon-Bibb Levee Seepage Repair**

**The Invitation for Bids, referenced above, is modified as follows:**

1. Question and Answer

**Question:** Note 3B on sheet 9 of 17 of the drawings requires the compacted soil fill to have particle size such that 40% passes the No. 200 sieve and 95 must pass the 2-inch sieve. Is that a minimum, maximum, or is there a range associated with that?

**Answer:** 40% is the **maximum** that can pass the NO 200 sieve. The 95% passing the 2-inch sieve is the **minimum** that is to pass it.

Please incorporate this change into the Invitation for Bid and acknowledge receipt of this addendum on your bid form.

Sincerely,

*Nan Tharpe*

Nan Tharpe  
Procurement Officer II