



**RENOVATION OF THE
GEORGIA SECRETARY OF STATE OFFICE BUILDING
237 Coliseum Drive / Macon, Georgia
BTBB No. 15-030**

17 June 2016

ADDENDUM NUMBER THREE

Bidders are advised that bidding documents on the above named project are amended as follows:

SPECIFICATIONS

1. Section B, Bid Form: On page 2 of the revised Bid Form issued in Addendum No. 2, change the paragraph regarding contract time to read as follows:
“Bidder hereby agrees to commence actual physical work on site, with an adequate force and equipment under this contract within ten (10) calendar days of a date to be specified in a written order from the Owner and to fully complete all Work within **one hundred eighty (180) consecutive calendar days** from and including said date.”

DRAWINGS

1. Sht E0.1: Under Notes, add the following:
“Provide one 20-amp, 110V connection to each face of sign. Conductors to each individual letter are routed concealed within the sign and are to be provided by the electrical contractor.”

END OF ADDENDUM