



Macon-Bibb County Government

Procurement Department

Government Center

700 Poplar Street, Suite 308

Macon, Georgia 31201

(478) 803-0550

Fax (478) 751-7252

Chauncey Wilmore
Senior Procurement Officer

April 10, 2018
ADDENDUM #1

To: ALL PROSPECTIVE FIRMS

Re: INVITATION FOR BIDS: **18-039-CW Henderson Stadium Fencing**

The Invitation for Bids, referenced above, is modified as follows:

1. What material should the tie wires be made of...steel or aluminum? This is an important question because the aluminum, though less expensive, is not safe. It will unravel due to its smooth, coated texture and weak durability. We recommend using steel, but we will install what you tell us to install. [Tie wires are to be steel](#)
2. The type of fasteners used on the existing fence going up the ends of the bleachers are steel gate clips that are crimped down to hold the wire. We recommend steel welded clips for more safety and strength, but again we will install what you tell us to install. So the question is...can the fence going up the stairs be fastened like the existing fence, or would you rather us use steel welded clips? [Use similar clips as currently being used.](#)
3. There is not any information about the fence post footings that will be installed in the dirt. What are the post footing requirements? Our recommendation is 7" wide by 28" deep filled with concrete. [All posts should be in a 7" by 28" deep hole filled with concrete](#)
4. Are the fittings (rail ends and loop caps) to made of steel or aluminum?
[All fittings should be made of steel](#)

Please incorporate this change into the Invitation for Bid and acknowledge receipt of this addendum on your bid form.

Sincerely,

Chauncey K. Wilmore

Chauncey K. Wilmore
Senior Procurement Officer