



Macon-Bibb County Government

Procurement Department

Government Center

700 Poplar Street, Suite 308

Macon, Georgia 31201

(478) 803-0550

Fax (478) 751-7252

February 10, 2021

ADDENDUM # 1

To: ALL PROSPECTIVE FIRMS

Re: INVITATION FOR BIDS: 21-027-FH North Macon Park – SPLOST - Construction

Questions and Answers

1. **The alternate #1 does not match the alternate schedule in the specifications.**

The highlighted alternate (from sheet P101) is in coordination with “Delete Alternate 1” in the specifications.

2. **Please confirm that the toilet partitions are being replaced & what material they need to be quoted as? They are not listed in the specifications.**

Yes, the toilet partitions will be replaced. The material is solid phenolic.

3. **Can the hardware be equal to the specified hardware?**

Hardware can be equal as long as it meets all of the test requirements and is approved by the owner.

Please incorporate this change into the Invitation for Bid and acknowledge receipt of this addendum on your bid form.

Sincerely,

A handwritten signature in blue ink, appearing to read "Frank A. Howard".

Frank A. Howard
Procurement Officer
fhoward@maconbibb.us
478-751-7651