



Macon-Bibb County Government

Procurement Department

Government Center

700 Poplar Street, Suite 308

Macon, Georgia 31201

(478) 803-0550

Fax (478) 751-7252

Franklin Lawson
Director of Procurement

May 24, 2021

ADDENDUM # 1

To: ALL PROSPECTIVE FIRMS

Re: INVITATION FOR BIDS: **Roof Replacement Bid # 21-056**

The Invitation for Bids, referenced above, is modified as follows:

Additional information for minimum requirements.

1. The existing downspout size is identified as 4" by 5" to be installed with 20' spacing between. In addition, down sprout to be installed down to the lean-to or equipment roof while maintaining the same 20' spacing.
2. The roof system is to be mechanically attached thru the roof purlins.
3. As a point of reference, the rib/ridge depth of the metal on the wall is not the same as the rib depth on the roof. The rib depth on the roof is 1 ¾" deep. Rib spacing is the same.
4. When submitting bids, vendor shall include a projected delivery and completion date for roof replacement. Completion date of roof replacement from the time of award can be modified if there are delays in shipping of materials with no monetary penalties.

Please incorporate this change into the Invitation for Bid and acknowledge receipt of this addendum on your bid form.

Sincerely,

Laura Hardwick
Senior Procurement Officer