



Macon-Bibb County Government

Procurement Department

Government Center

700 Poplar Street, Suite 308

Macon, Georgia 31201

(478) 803-0550

Fax (478) 751-7252

Laura Hardwick
Director of Procurement

April 9, 2023

ADDENDUM # 2

To: ALL PROSPECTIVE FIRMS

Re: INVITATION FOR BIDS: 23-035-LH, Installation of Network Cabling

The Invitation for Bids, referenced above, is modified as follows:

1. There are No specifications provided for the Wall Mount Cabinets – what size do you need, 9U, 12U, 22U.... Please provide details.

Answer: 12 U

2. Line item 3 – qty. 2 Cat 6 CMP. Are you looking for 2, 1000ft rolls of Cat 6 cabling? Please provide details.

3. Answer: Two Boxes of 1000Ft Cable.

4. Line item 4 – Outlet box, are you looking for surface mount single gang box with wire mold...etc. Please provide more details.

Answer: yes, with surface mount single gang box with wire mold.

5. Line item 5 – 2 Port Face plate, would you like a specific color, ivory, white, almond ...etc. Please provide details.

Answer: White.

6. Line item 6 – the BOM asked for 25 to 30 Cat 6 jacks, this is far more than the number of outlets and faceplates. Are you looking for extra jacks for spare parts inventory?

Answer: No. Total of 12 Jacks per Station. Data/Voice, Six phones per station.

7. Are all 17 Fire Stations currently in operation with personnel present?

Answer: Yes.

8. Will you make available to the contractors all the drawings and/or floor plans for each of the fire stations?

Answer: Yes, drawings will be provided.

9. Do you anticipate the cable runs to be hidden behind the walls or mounted on the wall surface inside wire mold? Please advise.

Answer: No cables will be surface mounted on walls inside wire mold.

10. Will maps be provided of each location that identifies the "Wall Mount Cabinet" location and location of the CAT6 data drops?

Answer: Maps will be provided for each location.

11. How are we to determine the quantity of CAT6 drops required for each location?

Answer: Vendors who attend the pre-mandatory will be able to go on site visits. There will be Six phones at each location, along with a data drop, 12 in all, voice/data.

12. Will site visits be allowed to each Fire Station?

Answer: Yes.

13. The bid from list specific parts, where do we include the cost for labor/installations?

Answer: This bid requires an all-inclusive cost. Therefore, overall total bid cost should include parts, labor, material, and equipment to complete the project.

14. The UPS or Equipment was not itemized. Should this be included?

Answer: UPS is not included.

15. When can the vendors visit the job sites:

Answer: Contact Mr. Edmund Strozier via email to schedule an onsite visit. His Email address is estrozier@maconbibb.us

16. Is there a list of the location sites?

Answer: See Attachment C posted to Macon-Bibb County Procurement website.

Please incorporate this change into the Invitation for Bid and acknowledge receipt of this addendum on your bid form.

Sincerely,

Laura Hardwick