

478.808.0391
wimberly@wimberlytreadwell.com
wimberlytreadwell.com
241 Stonehill Road | Forsyth, GA 31029
840 High Street | Macon, GA 31201

Bicentennial Park - Electrical - Bid

Electrical

Provide a single phase – 220 electrical service in the general location of the existing temporary service.

Service should be in a Macon-Bibb approved box that is lockable.

Inside the box should 4 a quad receptacle – coordinate with irrigation contractor so irrigation controller can house inside the box.

Outside the meter box in a weatherproof and lockable box should be a quad receptacle.