



Macon-Bibb County Government

Procurement Department

Government Center

700 Poplar Street, Suite 308

Macon, Georgia 31201

(478) 803-0550

Fax (478) 751-7252

Laura Hardwick
Director of Procurement

April 29, 2024

ADDENDUM # 2

To: ALL PROSPECTIVE FIRMS

Re: INVITATION FOR BIDS: 24-027-LH, Landfill Wastewater Pump System

The Invitation for Bids, referenced above, is modified as follows:

1. There are 10 models of the Thompson JSC ENVIROPRIME SYSTEM® SERIES PUMPS. The county spec of "Flows up to 10,500 gpm, Discharge heads up to 340 feet, Suction lift up to 28 feet, Solids handling up to 4 inches" describes the range of the 10 pumps, it is not specific to a particular model. To be more precise, Thompson doesn't have a model that will do 10,500 gpm with heads to 340 ft. And I don't believe their pump that would do 10,500 gpm would be mounted on a 2-wheel trolley. In fact, this would be such a large pump (18" suction) that I'd have to wonder if it could be wheel mounted at all. Can you tell us which exact model you are interested in?

Answer: Model 8JSCE.

2. Can you please clarify if we can send our bid directly to you by email?

Answer: Bids cannot be submitted by email. Please refer to the Invitation to Bid instructions.

Please incorporate this change into the Invitation for Bid and acknowledge receipt of this addendum on your bid form.

Sincerely,

Laura Hardwick