



Macon-Bibb County Government
Procurement Department
City Hall
700 Poplar Street, Suite 308
Macon, Georgia 31201
(478) 803-0550

Laura Hardwick
Director of Procurement

September 29, 2025

ADDENDUM # 2

To: ALL PROSPECTIVE FIRMS

Re: INVITATION FOR BIDS: 26-016-LH, Paving The Way Project 6

The Invitation for Bids, referenced above, is modified as follows:

1. Item #6 - Install Furnished Sewer Manhole, Storm Manholes. It is assumed that this item is for installing furnished risers. Please clarify that this is correct.

Answer: All risers will be furnished through Macon Water Authority.

2. On Park St. there are asphalt sections at House #246, the bridge, 200' on each side of the bridge and the last 200' at Forsyth Rd., the remaining sections of the road is concrete. Since a big portion of Park St. is concrete will Park St. just be overlaid or will the asphalt sections be milled and paved? Please clarify what milling and paving will be performed on this road.

Answer: The asphalt sections will be milled and repaved. The concrete section will be overlaid. Transitions will be needed to match between the asphalt and concrete sections.

3. There are traffic signals on both ends of Park St. and on Providence Blvd. Will the traffic signal loops be replaced at these locations? If so, a quantity is needed on the Bid Schedule.

Answer: The stamped concrete will be tied on both ends with asphalt pavement.

4. On Kimmeridge Dr. (Country Oaks Dr. to Van Dyke Cove) there is an existing stamped concrete section of roadway. Will this section remain and be tied to with the asphalt paving?

Answer: The stamped concrete will be tied on both ends with asphalt pavement.

5. Azalea Dr. (Club Trace to Greenfield Rd.) has been paved under the 25-030-LH contract in February 2025 contract. Please advise.

Answer: Do not include this street in your bid.

6. Item #6 - Install Furnished Sewer Manhole, Storm Manholes. It is assumed that this item is for installing furnished risers. Please clarify if this is correct.

Answer: All risers will be furnished through Macon-Water Authority.

7. What is the estimated budget?

Answer: To be determined.

Please incorporate this change into the Invitation for Bid and acknowledge receipt of this addendum on your bid form.

Sincerely,

Laura Hardwick