



Macon-Bibb County Government

Procurement Department

City Hall

700 Poplar Street, Suite 308

Macon, Georgia 31201

(478) 803-0550

Laura Hardwick
Director of Procurement

November 4, 2025

ADDENDUM # 1

To: ALL PROSPECTIVE FIRMS

Re: INVITATION FOR BIDS: 26-022-LH, Carolyn Crayton Park (Formerly known as Central City Park)
Softball Field #7 for Installation and Repairs.

The Invitation for Bids, referenced above, is modified as follows:

1. In the page C-2 under key notes for site demolition 4 it states "Sawcut, remove and dispose of existing paving in areas indicated for new work." The drawing does not show the locations of these items. Kindly clarify.

Answer: Existing paving is not anticipated in the work area.

2. On page C-16 the post and chain barrier detail is shown, we do not see in any location in the drawings, kindly clarify location and the length of the chain barrier and details on the post.

Answer: The chain barrier is not included in this project. Disregard details.

3. On page C-15 precast concrete manhole and catch basin details provided, we don't see in any location in the drawings, kindly clarify the location.

Answer: Grate Inlet A and Grate Inlet B are on the west and east side of Field 7. Location, Rim and Inverts for each catch basin are shown on C-5

4. Please let us know the exact location/address of field 7.

Answer: The address of the park is 150 Willie Smokie Glover Drive. The field itself does not have an address but is in the rear of Carolyn Crayton Park near the railroad crossing. It currently exists but looks abandoned. It is easy to locate once you are in the park.

Please incorporate this change into the Invitation for Bid and acknowledge receipt of this addendum on your bid form.

Sincerely,

Laura Hardwick