



Macon-Bibb County Government

Procurement Department

City Hall

700 Poplar Street, Suite 308

Macon, Georgia 31201

(478) 803-0550

Laura Hardwick
Director of Procurement

January 21, 2026

ADDENDUM # 2

To: ALL PROSPECTIVE FIRMS

Re: INVITATION FOR BIDS: 26-029-LH, Fire Station Alert System

The Invitation for Bids, referenced above, is modified as follows:

1. Clarification for Addendum 1 question #12.

“Regarding the requirement for redundant communication paths (Ethernet, Wi-Fi, and optional LTE/cellular failover with automatic failover) on page 6:

Can the County clarify whether bidders are required to provide redundancy across the communication paths as part of the proposed solution, or if this description reflects the County’s existing/current communications architecture?

“Previous answer: No. We are requesting redundancy from the vendor.”

Response to clarification request: There are network ports available at each fire station that the vendor would be able to utilize. Anything other than IP redundancy would need to be provided by the vendor.

Please incorporate this change into the Invitation for Bid and acknowledge receipt of this addendum on your bid form.

Sincerely,

Laura Hardwick