



Macon-Bibb County Government
Procurement Department
Government Center
700 Poplar Street, Suite 308
Macon, Georgia 31201
(478) 803-0550

Laura Hardwick
Director of Procurement

February 5, 2026

ADDENDUM # 2

To: ALL PROSPECTIVE FIRMS

Re: INVITATION FOR BIDS: 26-033-LH, Residential Roof Repairs for Twenty Houses

The Invitation for Bids, referenced above, is modified as follows:

1. Metal ridge vent was specified, but will shingle-over ridge vent be acceptable?

Answer: Yes shingle-over ridge vent is acceptable.

2. Are standard neoprene pipe flashings acceptable?

Answer: Yes, standard neoprene pipe flashings are acceptable.

3. We are from Albany and have a business license in Albany/Dougherty County; will we need a business license in Macon-Bibb in order to work?

Answer: No, a current business license where the business is located is what is required.

4. It says that sealed bids should be submitted 1 original (paper) and 1 flash drive, but in the pre-bid meeting it was stated that the paper copy was required but the digital version was never mentioned. Will a sealed envelope with only the paper bid be sufficient?

Answer: A paper copy and flash drive is required by the procurement department.

5. Houses that contained Lead Based Paint

Answer:

- 1) 2842 Kent Drive
- 2) 1063 Dennis Street
- 3) 936 Curry Drive
- 4) 2991 Millerfield Rd
- 5) 541 Villa Crest Avenue
- 6) 3920 Marse Allen Rd
- 7) 1314 Brinwood Drive
- 8) 2961 Jadan Place
- 9) 553 Lynmore Circle
- 10) 3041 O Hara Drive North
- 11) 2810 Alta Vista Ave

Please incorporate this change into the Invitation for Bid and acknowledge receipt of this addendum on your bid form.

Sincerely,

Laura Hardwick