



Macon-Bibb County Government

Procurement Department

City Hall

700 Poplar Street, Suite 308

Macon, Georgia 31201

(478) 803-0550

Laura Hardwick
Director of Procurement

September 24, 2026

ADDENDUM # 1

To: ALL PROSPECTIVE FIRMS

Re: INVITATION FOR BIDS: 27-003-LH, Bondsview Road Maintenance

The Invitation for Bids, referenced above, is modified as follows:

1. The cross drainpipes are not long enough for a 20' wide road. Do you make any changes to the cross drains such as headwalls, pipe extensions, or riprap?

Answer: There is no work at the cross drains. The 20 feet is a typical section distance. The roadway wide does vary, and material will be placed on the existing road only.

2. Do you clear the entire ROW?

Answer: Material is placed on the existing roadway. There are no ditch to be cut. There may be minor bushing that overhangs that may need to be cut back.

3. Can we substitute GABC for the crushed concrete base?

Answer: Crust concrete is required. GAB cannot be substituted.

4. Does the crushed concrete have to come from a recycler listed on GDOT QPL2?

Answer: The crust concrete must come from a GDOT QPL supplier.

5. Who will do the testing?

Answer: GDOT will be providing testing materials.

6. How will you determine the pay quantity for the crushed concrete?

Answer: Crust concrete is paid by the Cubic Yard and will be determined by truck ticket and verify by field placement. A weight ticket for delivery will also be need.

7. Do any subcontractors have to be GDOT registered?

Answer: GDOT qualified contractors are required.

8. Who do you submit the Davis-Bacon certified payrolls to? Who will review them?

Answer: They will be submitted to Macon Bibb Engineering and will be discussed at the Preconstruction Conference.

Please incorporate this change into the Invitation for Bid and acknowledge receipt of this addendum on your bid form.

Sincerely,

Laura Hardwick